



# Certificate

## Indoor Air Comfort Gold

**CLICK COLLECTION/55, CLICK COLLECTION/30**

*Products*

**Project Floors GmbH, Max-Ernst-Straße 4, 50354 Hürth**

*Manufacturer*

The products have undergone a successful testing and evaluation program as specified for Eurofins Indoor Air Comfort Gold certification, version 5.3a (2015). This includes a chamber test of emissions and aldehydes and a surveillance of the manufacturing site according to DIN 18200.

**The successful evaluation means compliance with the recent limits of legal regulations on low emitting products in Belgium, France (class A+) and Germany (AgBB), and several ecolabels:**

- ✓ No carcinogenic substances were detectable above their limit values, including 4 CMR substances regulated in France.
- ✓ Formaldehyde was below the limit value of 10 µg/m<sup>3</sup> and Acetaldehyde below of 200 µg/m<sup>3</sup>.
- ✓ Sum of VOC (TVOC) was below the limit values of 1000 µg/m<sup>3</sup> after 3 days and 160 µg/m<sup>3</sup> after 28 days. The product was classified A+ according to French VOC regulation.
- ✓ Sum of SVOC after 28 days was below the limit value of 30 µg/m<sup>3</sup>.
- ✓ The R values were below the limit value of 1 for both German NIK and Belgian LCI lists after 28 days. The sum of VOC without German LCI value was below 100 µg/m<sup>3</sup>.
- ✓ Quality management system and factory production control program at the production site are capable to ensure a continuous production of very low emitting products.
- ✓ Therefore the product qualifies for the Indoor Air Comfort Gold label.

Certificate No.: IACG-32-334012016-01-2016

Date: 20 December 2016

Validity of certificate: 20 December 2021, with annual surveillance and retesting



Head of the Certification Body

**Eurofins Certification Body VOC**  
Am Neuländer Gewerbepark 4  
21079 Hamburg, Germany  
Phone: +49 40 492 94 6815

[IAC-Certification@eurofins.com](mailto:IAC-Certification@eurofins.com)  
[www.indoor-air-comfort.com](http://www.indoor-air-comfort.com)

*Sampling, testing and evaluation were performed according to the standards CEN/TS 165165, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, EN 13419 each in the latest versions.*